

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 952

Date: 30/03/23

It is certified that an inspection team headed by Kajja Sahu
Sub Engineer. (Name of Officers
with designation) from Municipal Council Karali (Name of
Department/Office) inspected the Chawara, Vidyaapeeth
Khari, Karali Narsinghpur (Name & Address of
the School) on 31/03/23 and found that the Chawara, Vidyaapeeth
Khari, Karali Narsinghpur (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

Signature with Seal : मुख्य नगर पालिका अधिकारी
Name : Pragna Bunkar
Designation : C.M.O

To
Chawara, Vidyaapeeth
Khari Karali Narsinghpur

(Name & Address of the Institution)

District Water Testing Laboratory
(National Drinking Water Mission)

Public Health Engineering Department Division, Narsinghpur

DISTRICT NARSINGHPUR BLOCK KARELI VILLAGE KHERI

Sample Details

- (1) Date of Collection: 11-11-2023
 (2) Date of Analysis: 11-11-2023 to 12-11-2023
 (3) Detail of Source & Location (i): T.W. No. 2 CHANWARA VADYAPETH
 (4) Sample Collected by: T. V. S. RAM VISHWAKARMA

Narsinghpur

Result

S.No.	Characteristics	Unit	Desirable Limit	Permissible Limit	Results	Remarks
1	Temperature	Oc	-	-	25 C	
2	Taste	-	Aggregable	Aggregable	-	
3	Odour	-	Aggregable	Aggregable	-	
4	Colour	Pt Cobalt	5.0	25	0.5	
5	pH	pH Scale	6.5 to 8.5	Above 8.5	7.8	
6	Turbidity	N.T.U.	1	5	1.0	
7	Total Alkalinity	Mg/L	200	600	410	
8	Chloride	Mg/L	250	1000	35	
9	Total Hardness	Mg/L	200	600	310	
10	Calcium Hardness	Mg/L	75	200.0	230	
11	Magnesium Hardness	Mg/L	30	100	80	
12	Total Dissolved Solids	Mg/L	500	2000	185	
13	Iron	Mg/L	0.3	1.0	0.5	
14	Fluoride	Mg/L	1.0	1.5	0.55	Water
15	Nitrate	Mg/L	45	45	5.0	is
16	Residual Chlorine	Ppm	0.2	1	0.0	probable
17	Sulphate	Mg/L	100	400	18.5	
18	Manganese	Mg/L	0.10	0.30	0.0	
BACTERIOLOGICAL TEST						
19	Thermo Tolerant Coliform	100 ml	0.00	0.00	0.0	
20	Total Coliform	100 ml	0.00	0.00	0.0	

Tested By :- *R.P. Soren*

Herd
Chemist

Public Health Engineering
Division Narsinghpur

A. Karan
QUALITY MANAGER

Assistant Engineer
District Water Testing Laboratory
P.H.E. Division, Narsinghpur
Sub-Division Narsinghpur